

TEST REPORT FOR THE VERIFICATION OF COMPLIANCE OF POWER CONVERTER WITH:

NTS V2.1 SEPE + CORRECTION REV. 1.0 8/10/2021

Procedure: PE.T-LE-62

Test Report Number.....: **2221 / 0269-7**
Type.....: Grid Connected PV Inverter
Tested Model.....: **SIRIO-ES-50**
Variant Models.....: SIRIO-ES-60

APPLICANT

Name.....: **SGS Tecnos, S.A. (Certification Body)**
Address.....: C/ Trespaderne, 29 - Edificio Barajas 1
28042 Madrid (Spain)

HIRED BY

Name.....: **RIELLO UPS (RPS, SPA)**
Address.....: Viale Europa, 7 -ZAI- 37045 Legnago (VI), Italy

TESTING LABORATORY

Name.....: **SGS Tecnos, S.A. (Electrical Testing Laboratory)**
Address.....: C/ Trespaderne, 29 - Edificio Barajas 1
28042 Madrid (Spain)
Conducted (tested) by.....: Jorge Nicolás
(Project Engineer)



Reviewed and Approved by.....: Miguel Rodriguez
(Technical Reviewer)

Date of issue.....: 27/07/2023
Number of pages.....: 42
Attachments and pages.....: **2221 / 0269-7 Attachment.I Rev.0** including 139 pages
Total Number of pages.....: 181

Important Note:

- This document is issued by the Company under its General Conditions of service accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents.
- Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.
- Unless otherwise stated the results shown in this test report refer only to the sample(s) tested as received. Information of derived or extension models of the range as provided by the applicant, (if any), is included in this report only for informative purposes. The Company SGS shall not be liable for any incorrect results arising from unclear, erroneous, incomplete, misleading or false information provided by Client. This document cannot be reproduced except in full, without prior approval of the Company.

Data Provided By The Client:

The following data has been provided by the applicant:

1. Any Information regarding Technical characteristics of the equipment, (Ratings, operation modes, software and hardware versions, dimensions & weight).
2. Equipment operation & construction information (Manuals, Electrical diagrams, information about components, Operation procedures).
3. Documental Information (Brand and models names, address or other information about applicant, company or manufacturer information).
4. Other information remarked within this report.

SGS TECNOS declines any responsibility with respect to the information provided by the applicant and that it may affect to the validity of results. It is not covered by ENAC accreditation.

Test Report Historical Revision:

Test Report Version	Date	Summary of changes
2221 / 0269-7	27/07/2023	First issuance

INDEX

- 1 SCOPE4**
- 2 GENERAL INFORMATION.....5**
 - 2.1 Testing Period and Climatic conditions5
 - 2.2 Equipment under Testing5
 - 2.3 Reference Values9
 - 2.4 Test equipment list10
 - 2.5 Measurement uncertainty and Data Sampling Rates12
 - 2.6 Test set up.....13
 - 2.6.1 AC Voltage source verification13
 - 2.7 Definitions.....14
- 3 SUMMARY OF TEST RESULTS 15**
- 4 TEST RESULTS 16**
 - 4.1 Frequency requirements16
 - 4.1.1 Active power feed-in as a function of frequency16
 - 4.2 Active Power Requirements.....22
 - 4.3 Inertia Emulations22
 - 4.4 Reactive Power Requirements.....23
 - 4.4.1 Reactive power capability23
 - 4.4.2 Reactive power control.....27
 - 4.5 Control of oscillation damping35
 - 4.6 Response during grid faults35
 - 4.7 Islanding requirements39
- 5 PICTURES.....40**
- 6 ELECTRICAL SCHEMES42**

1 SCOPE

SGS Tecnos, S.A. (Electrical Testing Laboratory) has been contracted by SGS Tecnos, S.A. (Certification Body) in order to perform the testing for UGE according to:

NTS SEPE

- "Norma Técnica de Supervisión (NTS) de la conformidad de los Módulos de Generación de Electricidad según el Reglamento UE 2016/631". Revisión 2.1 (09/07/2021).
- "Corrección de errores de la versión 2.1 (del 9/7/2021) de la Norma Técnica de Supervisión de la Conformidad de los Módulos de Generación de Electricidad según el Reglamento UE 2016/631". Revision 1.0 del (08/10/2021).

The Equipment Under Testing (EUT) is an UGE, without inertia, nonsynchronous. For the purpose of evaluation, the EUT is considered to be a **Type A**, and **Type B** UGE, as defined in the standard:

- Type A: At the point of connection, $V < 110 \text{ kV}$, $0.8 \text{ kW} \leq P \leq 100 \text{ kW}$.
- Type B: At the point of connection, $V < 110 \text{ kV}$, $100 \text{ kW} < P \leq 5 \text{ MW}$.
- Type C: At the point of connection, $V < 110 \text{ kV}$, $5 \text{ MW} < P \leq 50 \text{ MW}$.
- Type D: At the point of connection, $V \geq 110 \text{ kV}$, $P > 50 \text{ MW}$.

2 GENERAL INFORMATION

2.1 TESTING PERIOD AND CLIMATIC CONDITIONS

Testing has been performed between two periods:

- From May 6th to November 3rd, 2022
- From July 19th to July 24th, 2023.

All the tests and checks have been performed at climatic conditions:

Temperature	25 ± 10 °C
Relative Humidity	50 ± 20 %
Pressure	90 ± 10 kPa

SITE TEST

Name.....: **SGS Tecnos, S.A. (Electrical Testing Laboratory)**
Address: C/ Trespaderne, 29 - Edificio Barajas 1
28042 Madrid (Spain)

2.2 EQUIPMENT UNDER TESTING

The following information has been provided by the manufacturer:


Apparatus type: Three Phase Photovoltaic Inverter
Installation: Wall mounted Installation
Manufacturer: RIELLO SOLARTECH
Trademark.....: 
Model / Type reference: **SIRIO-ES-50**
Serial Number: AM42SPSE0000139
Software Version.....: V013133
Rated Characteristics.....: Input: MPPT 200 – 960 V_{dc}; V_{max}: 1100 V_{dc}; V_n: 620 V_{dc};
I_{dc_max} = 33/33/22/22 A_{dc}; I_{sc} = 42/42/28/28 A_{dc}
Output: 400 V_{ac}; 50/60 Hz; I_n: 3x76 A_{ac}; I_{max}: 3x83 A_{ac};
I_n: 3x76A; S_{max}: 55 kW, P_n: 50kW

Date of manufacturing: 2021

Test item particulars

Input: DC
Output: 3/N/PE
Class of protection against electric shock...: Class I
Degree of protection against moisture: IP 65
Type of connection to the main supply: Three phase – Fixed installation
Cooling group.....: Forced ventilation (Fan)
Modular: No
Internal Transformer: No

Copy of marking plate (representative):



Note:

1. The above markings are the minimum requirements required by the safety standard. For the final production samples, the additional markings which do not give rise to misunderstanding may be added.
2. Label is attached on the side surface of enclosure and visible after installation.

	Report N. 2221 / 0269-7	Page 7 of 42
NTS-V2.1 (09/07/2021) + Correction (08/10/2021) UGE Evaluation		

Equipment under testing:

- SIRIO-ES-50

Variant models:

- SIRIO-ES-60

The variant models can be included in this test report without tests because the following features don't change in comparison with the tested model:

- Same topology of power stages. That is, the same arrangement of conversion stages, the same location of filters, the same location of relays, etc.
- Same isolation class (low-frequency transformer, high-frequency transformer or no transformer).
- Same AC connection state (1-phase or 3-phase).
- Nominal alternating current $\pm 50\%$ with respect to the type tested.
- Same control algorithm for all technical requirements.
- Groupings of several power stages (modular systems) shall be considered valid without the need for repeating tests.

The results obtained apply only to the particular sample tested that is the subject of the present test report.

The most unfavourable result values of the verifications and tests performed are contained herein. Throughout this report a point (comma) is used as the decimal separator.

The following table shows the full ratings of all models referenced in this report:

MODELO	SIRIO ES 50	SIRIO ES 60	SIRIO ES 100	SIRIO ES 110
ENTRADA				
Voltaje máximo de entrada [V]	1100			
Corriente máxima de entrada [A]	2x39 + 2x26	4x39	3x40 + 5x32	3x40 + 6x32
Corriente máxima de cortocircuito [A]	2x42 + 2x28	4x42	3x50 + 5x45	3x50 + 6x45
Realimentación máxima	OA			-
Voltaje nominal [V]	620		600	
Rango del voltaje de operación del MPPT [V]	200 + 1100			
Grado de sobretensión	II			
Número máximo de entradas	10 (3/3/2/2)	12 (3/3/3/3)	16 (8x2)	18 (9x2)
Número de rutas del MPPT	4		8	9
Protección de sobrecarga [V]	Fuse, 16A/1100			
SALIDA				
Potencia nominal de salida [W]	50000	60000	100000	110000
Potencia aparente máxima [VA]	55000	66000	110000	123000
Potencia activa máxima [W]	55000	66000	110000	121000
Corriente de salida nominal [A]	3x83	3x92	3x168.8	3x187
Voltaje nominal de la red eléctrica [V]	380 / 400, 3W+N+PE		380 / 400 / 415, 3W+N+PE	
Voltaje de la red eléctrica [V]	277 + 520 (configurable)			
Frecuencia nominal de la red eléctrica [Hz]	50 / 60			
Rango de frecuencia de la red eléctrica [Hz]	45-55 / 55-65		45-55 / 55-65 (configurable)	
THDi [%]	< 3 % (potencia nominal)			
CC off-sets [%]	< 0.5 in			
Factor de potencia	> 0.99 potencia nominal (regulable 0.8 inductivo - 0.8 capacitivo)			
Grado de sobrecarga según IEC 62109-1	III			
PROTECCIÓN				
Protección del sistema	Interruptor de entrada de CC, entrada para protección para sobrecargas, entrada para protección de conexión inversa, detección de fallos en el string fotovoltaico, detección de resistencia térmica, paso de bajo tensión, salida para protección de sobrecargas, protección DDR, protección de CC off sets, protección para sobrecalentamiento, protección anti-islanding, protección de sobretensión o baja tensión de CA/CC, protección de alta o baja frecuencia de CA			-
Pararrayos CA/CC	Soportado: II tipo, Máximo 40KA			-
SISTEMA				
Maximum efficiency [%]	98.3		98.4	
European Efficiency [%]	98			
Topología	Sin transformador			
Nivel de protección	IP65		IP66	
Grado de contaminación	PD3		-	
Refrigeración	Forzado con ventiladores de velocidad controlada			
MONITOR Y COMUNICACIONES				
Monitor	Wireless por APP + LED/LCD			
Comunicaciones	Bluetooth, RS485, Wi-Fi (opcional), Ethernet (opcional)		Bluetooth, 2xRS485, Wi-Fi (opcional), Ethernet (opcional)	
PARÁMETROS MEDIOAMBIENTALES				
Temperatura del rango operativo [°C]	-25 + 60			
Humedad relativa	0 + 100			
Altitud máxima operativa [m]	4000			
Ruido [dB] (@ 1 m)	<62		≤65 (típico)	
INSTALACIÓN FÍSICA				
Dimensiones (WxDxH) [mm]	855x275x500		936x365x678	
Peso [kg]	73	74	92	
Modelo de instalación	Soporte para montar el inversor			
Conector de entrada	Amphenol H4			
Conector de salida	Conector resistente al agua + Terminal OT			
CUMPLIMIENTO DE LA NORMATIVA				
Estándar de la corriente eléctrica	NB / T32004			
Certificado de seguridad	IEC62109-1, IEC62109-2, N B / T32004			
EMC	EN 61000-6-2/4			
Reglamento	CEI 0.21 & CEI 0.16 - RD1699, RD 661, RD 413, UNE 206006, UNE 206007-1, UNE 217002, UNE 217001/RD244/RD647, NTS			
Garantía	5 años			

2.3 REFERENCE VALUES

The values presented in the following table have been used for calculation of referenced values (p.u.; %) through the report if not otherwise indicated.

Reference Values	
Rated power, P_n in kW	50
Max. Active power, P_{max} in kW	55
Rated apparent power, S_n in kVA	55
Max. apparent power, S_{max} in kVA	55
Rated wind speed (only WT), v_n in m/s	Not applicable
Rated current (determined), I_n in A	79.7
Rated output voltage, (phase to phase) U_n in Vac	400
Note: In this report p.u. values are calculated as follows: -For Active & Reactive Power p.u values are reference to P_n -For Currents p.u values, the reference is always I_n -For Voltages p.u values, the reference is always U_n	
Rated current has been determined as follows: $I_n = S_{max} / (U_n \cdot \sqrt{3})$	

2.4 TEST EQUIPMENT LIST

The following table shows measurement equipment used in tests:

From May 6th to November 3rd, 2022

No	EQUIPMENT	MARK/MODEL	SGS CODE(DIE)	CALIBRATION DATE
1	Power Analyzer	YOKOGAWA / WT3000	DIE.510014	12/08/2021 to 12/08/2022
2	Data Acquisition Equipment	DEWESsoft / SIRIUSi-4xHV-4xLV	DIE.630044	15/12/2021 to 15/12/2022
3	Digital Thermohygrometer	TESTO / 622	DIE.840050	19/10/2021 to 19/01/2023
4	Current Clamp	HIOKI / 9660	DIE.510012-1	05/02/2021 to 05/02/2023
5	Current Clamp	HIOKI / 9660	DIE.510012-2	05/02/2021 to 05/02/2023
6	Current Clamp	HIOKI / 9660	DIE.510012-3	05/02/2021 to 05/02/2023
7	Current Clamp	HIOKI / 9660	DIE.510012-4	05/02/2021 to 05/02/2023
8	Digital Multimeter Current Clamp	HIOKI / 3285	DIE.510051	15/05/2021 to 15/05/2022 30/05/2022 to 30/05/2023
9	True Multimeter	FLUKE / 289	DIE.560040	20/12/2021 to 20/12/2022
10	MATLAB Function	SGS / RMS+Power	DIE.001461-1	15/02/2019 to --
11	MATLAB Function	SGS / VoltageChangeMeasures	DIE.001461-2	15/02/2019 to --
12	MATLAB Function	SGS / Sequences	DIE.001461-3	07/03/2019 to --
13	MATLAB Function	SGS / Static+MobileWindow	DIE.001461-4	10/06/2019 to --
14	MATLAB Function	SGS / Parameter	DIE.001461-5	14/02/2019 to --

Note:

1. All measurement equipment was used inside their corresponding calibration period. Copy of all calibration certificates are available at the laboratory for reference.
2. Since those are mathematical functions there is no need to establish a final calibration date.

From July 19th to July 24th, 2023.

No	EQUIPMENT	MARK/MODEL	SGS CODE(DIE)	CALIBRATION DATE
1	Power Analyzer	YOKOGAWA / WT3000	DIE.510014	12/08/2022 to 12/08/2023
2	Digital Thermohygrometer	TESTO / 622	DIE.840050	31/01/2023 to 01/05/2024
3	Current Clamp	HIOKI / 9660	DIE.510012-1	15/02/2023 to 15/02/2025
4	Current Clamp	HIOKI / 9660	DIE.510012-2	15/02/2023 to 15/02/2025
5	Current Clamp	HIOKI / 9660	DIE.510012-3	15/02/2023 to 15/02/2025
6	Current Clamp	HIOKI / 9660	DIE.510012-4	15/02/2023 to 15/02/2025
7	Digital Multimeter Current Clamp	HIOKI / 3285	DIE.510051	29/06/2023 to 29/06/2024
8	True Multimeter	FLUKE / 289	DIE.560040	19/12/2022 to 19/12/2023
9	MATLAB Function	SGS / RMS+Power	DIE.001461-1	15/02/2019 to --
10	MATLAB Function	SGS / VoltageChangeMeasures	DIE.001461-2	15/02/2019 to --
11	MATLAB Function	SGS / Sequences	DIE.001461-3	07/03/2019 to --
12	MATLAB Function	SGS / Static+MobileWindow	DIE.001461-4	10/06/2019 to --
13	MATLAB Function	SGS / Parameter	DIE.001461-5	14/02/2019 to --

Note:

3. All measurement equipment was used inside their corresponding calibration period. Copy of all calibration certificates are available at the laboratory for reference.
4. Since those are mathematical functions there is no need to establish a final calibration date.

2.5 MEASUREMENT UNCERTAINTY AND DATA SAMPLING RATES

Associated uncertainties through measurements showed in this this report are the maximum allowable uncertainties.

Magnitude	Uncertainty
Voltage measurement	±1.5 %
Current measurement	±2.0 %
Frequency measurement	±0.2 %
Time measurement	±0.2 %
Power measurement	±2.5 %
Phase Angle	±1°
Temperature	±3° C
Note1: Measurements uncertainties showed in this table are maximum allowable uncertainties. The measurement uncertainties associated with other parameters measured during the tests are in the laboratory at disposal of the petitioner. Note2: Where the standard requires lower uncertainties that those in this table. Most restrictive uncertainty has been considered and would be reported in this report.	

The following measurements uncertainties have been verified by the used equipment (Oscilloscopes and/or Power Analysers) as specifically required by the standard for the performance of the testing process:


Magnitude	Measurement uncertainty requirement	Maximum uncertainty Test equipment used
Voltage (Fundamental frequency)	≤ 0.5 % of Un	± 0.06 %
Current (Fundamental frequency)	≤ 0.5 % of In	± 0.4 %
Frequency	±10mHz (±0.02%)	± 6.6 mHz

Data sampling rates have been applied as follows:

Magnitude	Data sampling (requested by standard)	Data sampling (used for testing)
Voltage measurements	≥ 3 kHz	> 10 kHz
Current measurements	≥ 3 kHz	> 10 kHz
Robustness Requirements	≥ 10 kHz	≥ 20 kHz

2.6 TEST SET UP

Below is the simplified construction of the test set up.



Different equipment has been used to take measures as it shown in chapter 2.4. Current and voltage clamps have been connected to the inverter input / output for all the tests.

All the tests described in the following pages have used this specified test setup.

The test bench used includes:

EQUIPMENT	MARK / MODEL	RATED CHARACTERISTICS	OWNER / ID. CODE
AC Power Source	CINERGIA / GE&EL+50 vAC/DC	0-400 V 50/60Hz 3x73A	DIE.501051
DC Power Source	CINERGIA / GE+50 vAC/DC	0-800 V _{dc} 3x50A	DIE.501053

2.6.1 AC Voltage source verification

According to point 5 of the standard, the accuracy of the equipment used as a source of voltage and frequency shall comply with the following requirements:

- Unbalance of the AC voltage $\mu < 0.5\%$
- Harmonics of Voltage source THD $< 1\%$

Variable	Required	Measured	Result
Unbalance (μ)	$< 0.5\%$	0.02%	Pass
THD	$< 1.0\%$	0.18%	Pass

2.7 DEFINITIONS

A	Ampere	PGU	Power Generation Unit
EUT	Equipment Under Testing	P_{ini}	Pre-disturbance active power of the UGE
Exp	Expected	P_M	Instantaneous Active Power
Hz	Hertz	P_n	Nominal Active Power
I_h	Harmonic Current	PPC	Power Plant Controller
I_n	Nominal Current	P_{st}	Short-term flicker disturbance factor
I_{q+}	Reactive Current in positive sequence	Q_n	Nominal Reactive Power
I_{q-}	Reactive Current in negative sequence	Sk	Symmetrical Fault level
LV	Low Voltage	S_n	Nominal Apparent Power
LVRT	Low Voltage Ride Through	TDC	Total Demand Current Distortion
Meas.	Measured	TDD	Total Demand Distortion
MGE	Electrical Generation Module (can be either MPE or MGES)	TSO	Transmission System Operator
MGES	Electrical Synchronous Generation Module	UGE	Energy Generation Unit
MPE	Electrical Park Module	U_n	Nominal Voltage
MV	Medium Voltage	V	Volt
NCP	Network connection point	VAr	Volt-Ampere reactive
p.u.	Per unit	W	Watt

3 SUMMARY OF TEST RESULTS

INTERPRETATION KEYS

- Test object does meet the requirement..... : **P** Pass
- Test object does not meet the requirement : **F** Fails
- Test specification/standard does not include limits : **P*** ..Performed
- Test case does not apply to the test object..... : **N/A** Not applicable
- To make a reference to a table or an annex. : See additional sheet
- To indicate that the test has not been realized : **N/P** Not Performed

NTS SEPE SECTION	TRF SECTION	CHAPTER OF THE STANDARD	TYPE ⁽¹⁾	RESULT
		NTS		
--	4.1	Frequency Requirements	--	P
--	4.1.1	Active power feed-in as a function of frequency	--	P
5.1	4.1.1.1	Limited Frequency Sensitive Mode-Overfrequency (LFSM-O)	≥A	P
5.2	--	Power-frequency regulation mode limited to underfrequency (LFSM-U)	≥C	N/A
5.3	--	Frequency Sensitive Mode (FSM)	≥C	N/A
5.4	--	Power-Frequency Control	≥C	N/A ⁽²⁾
5.5	4.2	Active power control capability and range	≥C	N/A
5.5	--	Static error test	≥C	N/A
5.5	--	Dynamic response test	≥C	N/A
5.6	4.3	Inertia Emulations	≥C	N/A
--	4.4	Reactive Power Requirements	--	P
5.7	4.4.1	Reactive power capabilities at the EUT rated power and below	≥B	P
5.8	4.4.2	Reactive power control modes	≥B	P
5.10	4.5	Control of oscillation damping	≥C	N/A
--	4.6	Robustness Requirements	--	P
5.11	4.6	Capability to withstand voltage grid faults for POC below 110 kV	≥B	P
5.11	--	Capability to withstand voltage grid faults for POC above 110 kV	D	N/A
5.11	4.6	Rapid current injection control	≥B	P
5.11	4.6	Active power recovery after a grid fault	≥B	P
5.13	4.7	Islanding requirements	≥C	N/A

⁽¹⁾ Type ≥A means that the corresponding chapter applies to equipment of type A, B, C and D. The same criteria have been applied for the rest of types.

⁽²⁾ According to the standard, evaluation of this requirement will be carried out by the TSO in accordance with the test protocols established in the regulations in force at the time of commissioning of the MGE, which the TSO will indicate to the owner of the MGE.

Note: Decision Rule of Statements of conformity evaluated according to Guidelines ILAC G8:09/2019 and IEC 115:2023 (4.3.3 / 4.4) & ISO/IEC Guide 98-4 (8.3.12).

Decision Rules used: Binary Statement for Simple Acceptance (Guard Band with respect to the limit w=0). Specific Risk: Probability of False Accept or Reject lower than 50 %, (PFA / PFR < 50 %).

Measurement uncertainty is not applied when statements of conformity is the simple acceptance. For more information see ILAC G8/09 & 115 Guidelines.

4 TEST RESULTS

4.1 FREQUENCY REQUIREMENTS

4.1.1 Active power feed-in as a function of frequency

The aim of the test is to demonstrate the response of the EUT due to a deviation in grid frequency from rated value in terms of speed (rise/settling time) and the active power gradient.

4.1.1.1 Overfrequency (LFSM-O)

This test has been done to verify the capacity of the EUT of activating the automatic response for active power reduction due to over frequency variations according to section 5.1.2 of the standard.

Different tests have been carried out, regarding different droop levels and activation thresholds:

- OS2F2: droop $S_2= 2\%$ and activation threshold of $\Delta f_1 = 0.2$ Hz (50.2 Hz).
- OS2F5: droop $S_2= 2\%$ and activation threshold of $\Delta f_1 = 0.5$ Hz (50.5 Hz).
- OS12F2: droop $S_2= 12\%$ and activation threshold of $\Delta f_1 = 0.2$ Hz (50.2 Hz).
- OS12F5: droop $S_2= 12\%$ and activation threshold of $\Delta f_1 = 0.5$ Hz (50.5 Hz).

Active power variation for a specific step is calculated using the following expression:

$$|\Delta P| = \frac{|\Delta f| - |\Delta f_1|}{f_n} \times \frac{P_{max}}{S_2} \times 100$$

The following conditions have been evaluated for each test performed.

Criteria	Comments	Result
CONDITIONS DURING MEASUREMENTS		
A power supply connected to the terminals of the UGE when the UGE is disconnected from the mains.		P
UGE is connected to the mains.		N/A
Frequency variation method		P
A device (internal or external) introducing a digital or analogue input into the UGE control system.		N/A
A direct change of the frequency reference value in the control system of the PGU.		N/A
Direct modification of the frequency in the terminals of the UGE when the power supply has the capacity to modify the output frequency.		P
Test conditions		P
LFSM-U and FSM have been deactivated		P
Voltage has been at $U_n \pm 5\%$ during tests		P
Tests have been performed at P_n with set $Q=0$		P
Every step should be measured during >1 min.		P
GENERAL		
There are no oscillations that are not amortigated as a response to an abrupt change		P
Maximum deviations of active power according to the measured level of frequency shall not deviate more than $5\%P_n$		P
Results comply with the following criteria from reference standards		P
APPLICABLE FOR ACTIVE POWER REDUCTIONS		
Ta requirements		P
For type A & B MGE without inertia ≤ 2 s		P
For type C & D T_a is less than or equal to the power response activation time set for the MRPF mode (max 0.5 s MGE without inertia) because it defines the technical capability of the MPE power response.		N/A
If t_a exceeds 2 s: the PGM owner shall provide the TSO with technical evidence to justify this value as established in the Regulation. If the TSO accepts the justification, the TSO shall give its written consent to the PGM owner, who shall forward it to the authorised certifier for incorporation in the final PGM certificate.	No T_a exceeds 2 s.	N/A
Tr Requirements		P
For MGES UGE: less than or equal to 8 s for an active power variation of up to 45% of the maximum power.	UGE MPE Evaluated	N/A
For MPE UGE: less than or equal to 2 s for an active power variation of up to 50% of the maximum power.		P
Te Requirements		P
For MGES UGE: less than or equal to 30 s.	UGE MPE Evaluated	N/A

Criteria	Comments	Result
For MPE UGE: less than 20 s.		P
APPLICABLE FOR ACTIVE POWER INCREMENTS		
Ta requirements		P
For type A & B MGE without inertia ≤ 2 s		P
For type C & D Ta is less than or equal to the power response activation time set for the MRPF mode (max 0.5 s MGE without inertia) because it defines the technical capability of the MPE power response.		N/A
Tr Requirements		P
For MGES UGE: less than or equal to 5 minutes for an active power variation of up to 20% of the maximum power. This slow behaviour will not be acceptable when the direction of the frequency variation is reversed a few seconds before, in which case response times similar to the case of active power reduction will be expected.	UGE MPE Evaluated	N/A
For non-wind MPE UGE: less than or equal to 10 s for an active power variation of up to 50% of the maximum power.		P
For wind MPE UGE: less than or equal to 5 s for an active power variation of up to 20% of the maximum power if the power is above 50% of the maximum power. For powers less than 50% of the maximum power, the response time will be as low as technically possible.	Non-wind MPE UGE evaluated	N/A
Te Requirements		P
For MGES UGE: less than or equal to 6 minutes. This slow behaviour will not be acceptable when the direction of the frequency variation has reverted a few seconds before, in which case, response times similar to the case of active power reduction will be expected.	UGE MPE Evaluated	N/A
For MPE UGE: less than 30 s.		P

Results are presented in the following graphs and tables, where:

Ta Activation time: Time from a change on frequency that leads to a power frequency change of more than 1%, to the start of active power response.

Tr Response time: Time to reach the 90% of the measured active power response (ΔP), without including Ta.

Te Settling time: Time of settling of active power on a tolerance of $\pm 5\%$ of the measured active power response (ΔP).

OS2F2 (S=2%; Fstart=50.2 Hz)								
Step	Sim, f (Hz)	Meas, f (Hz)	Expected P (%P _{max})	P _{test} measured (%P _{max})	Deviation (%P _{max}) (<5%P _{max})	Ta (s)	Tr (s)	Te (s)
0	50.00	50.00	100% ± 5%	102.3%	+2.3%	--	--	--
1	50.10	50.10	100% ± 5%	102.3%	+2.3%	--	--	--
2	50.50	50.50	70% ± 5%	72.0%	+2.0%	0.2	1.1	1.4
3	50.70	50.70	50% ± 5%	49.6%	-0.4%	0.1	1.0	1.3
4	50.50	50.50	70% ± 5%	71.9%	+1.9%	0.1	0.8	1.4
5	50.10	50.10	100% ± 5%	99.0%	-1.0%	--	--	--
6	50.70	50.70	50% ± 5%	46.7%	-3.3%	0.1	1.1	1.4

Supplementary information:
 - % Values given with reference Pmax, in this case Pmax=55 kW

OS2F5 (S=2%; Fstart=50.5 Hz)								
Step	Sim, f (Hz)	Meas, f (Hz)	Expected P (%P _{max})	P _{test} measured (%P _{max})	Deviation (%P _{max}) (<5%P _{max})	Ta (s)	Tr (s)	Te (s)
0	50.00	50.00	100% ± 5%	99.5%	-0.5%	--	--	--
1	50.40	50.40	100% ± 5%	99.5%	-0.5%	--	--	--
2	50.80	50.80	70% ± 5%	71.7%	+1.7%	0.10	0.10	0.10
3	51.00	51.00	50% ± 5%	49.9%	-0.1%	0.10	0.10	0.10
4	50.80	50.80	70% ± 5%	70.0%	0.0%	0.10	0.30	0.30
5	50.10	50.10	100% ± 5%	99.5%	-0.5%	--	--	--
6	51.00	51.00	50% ± 5%	49.4%	-0.6%	0.10	0.10	0.10



Supplementary information:
 - % Values given with reference Pmax, in this case Pmax=55 kW



OS12F2 (S=12%; Fstart=50.2 Hz)								
Step	Sim, f (Hz)	Meas, f (Hz)	Expected P (%P _{max})	P _{test} measured (%P _{max})	Deviation (%P _{max}) (<5%P _{max})	Ta (s)	Tr (s)	Te (s)
0	50.00	50.00	100% ± 5%	99.0%	-1.0%	--	--	--
1	50.10	50.10	100% ± 5%	99.0%	-1.0%	--	--	--
2	51.40	51.40	80% ± 5%	80.0%	0.0%	0.1	1.1	1.5
3	50.30	50.30	98.3% ± 5%	97.2%	-1.1%	0.1	0.8	1.3

Supplementary information:
 - % Values given with reference Pmax, in this case Pmax=55 kW

OS12F5 (S=12%; Fstart=50.5 Hz)								
Step	Sim, f (Hz)	Meas, f (Hz)	Expected P (%P _{max})	P _{test} measured (%P _{max})	Deviation (%P _{max}) (<5%P _{max})	Ta (s)	Tr (s)	Te (s)
0	50.00	50.00	100% ± 5%	99.0%	-1.0%	--	--	--
1	50.40	50.40	100% ± 5%	99.0%	-1.0%	--	--	--
2	51.40	51.40	85% ± 5%	85.6%	+0.6%	0.2	1.1	1.4
3	50.60	50.60	98.3% ± 5%	0	-1.1%	0.1	0.7	1.5

Supplementary information:
 - % Values given with reference Pmax, in this case Pmax=55 kW





4.1.1.2 Underfrequency (LFSM-U)

This point of frequency requirements is not applicable since the EUT is considered as Type B, and the requirements of this subclause apply only to Type C and/or Type D PGUs.

4.1.1.3 Frequency Control (LFSM)

This point of frequency requirements is not applicable since the EUT is considered as Type B, and the requirements of this subclause apply only to Type C and/or Type D PGUs.

4.1.1.4 Power Frequency Control

The compliance with section 5.4 Power Frequency Control Capability, on these tests UGE it is considered to have no influence. Compliance shall be determined by evaluation from GRT needed.

4.2 ACTIVE POWER REQUIREMENTS

This point of active power requirements is not applicable since the EUT is considered as Type B, and the requirements of this subclause apply only to Type C and/or Type D PGUs.

4.3 INERTIA EMULATIONS

This point is not applicable since the type of compliance assessment method for these requirements is not a test to be done over the EUT. The grid operator shall evaluate the compliance with the requirements stated in clause 5.6 of the NTS standard using as a reference the simulation methods defined in this point of the standard. The conformity shall be confirmed by the grid operator through written communication.

4.4 REACTIVE POWER REQUIREMENTS

Through this point the reactive power sign criteria is in the point of view of the generator. Reactive Inductive power has positive sign and Reactive Capacity power has negative sign.

4.4.1 Reactive power capability

The aim of this test is to evaluate the reactive power capability of the EUT at different active power levels.

Criteria	Comments	Result
CONDITIONS DURING MEASUREMENTS		
The test conditions may be some of the following:		P
A power supply connected to the terminals of the UGE when the UGE is disconnected from the mains.		P
An element or method capable of modifying the voltage at the UGE connection point when the UGE is connected to the mains.		N/A
A fictitious signal simulating voltage changes connected to the UGE controller. The UGE must behave as if this signal were the voltage reading on its terminals.		N/A
Test bench, including all elements of reactive power management.		N/A
The voltage values indicated for the tests are considered nominal values of the configuration under which each step of the test is performed, configurations with a value of $\pm 2.5\%$ of the nominal voltage on the proposed values will be admitted.	All the levels measured have been maintained to the desired level $\pm 2.5\%$	P
TEST SEQUENCE		
The reactive power control mode of the UGE will be selected to setpoint of fixed reactive power.	UGE Configuration: -Qmax inductive -Qmax capacitive Except required by NTs, the manufacturer shall define the relationship between voltage, and reactive power at normal temperature.	P
The tests steps described in Table 17 of the standard have been carried out.		P



4.4.1.1 Reactive power capability (Required by NTs standard)

Q capability – Capacitive							
Step	Active Power Setpoint (%Pmax)	Active Power measured (%Pmax)	Voltage setpoint (%Un)	Voltage measured (%Un)	Q _{max} Capacitive (%Pmax)	Q _{max} Capacitive (kVAr)	Test duration
1	>90%	90.7%	95.00%	95.0%	-41.4%	-22.7	>60 min
2	>90%	90.4%	105.00%	105.0%	-61.1%	-33.6	>60 min
3	>90%	90.2%	100.00%	100.1%	-52.2%	-28.7	>5 min
4	10-20%	15.0%	95.00%	95.0%	-98.6%	-54.2	>5 min
5	10-20%	14.4%	105.00%	105.0%	-100.3%	-55.1	>5 min
6	10-20%	14.6%	100.00%	100.0%	-100.5%	-55.3	>5 min
7	0-10%	5.8%	95.00%	95.0%	-98.8%	-54.3	>5 min
8	0-10%	5.3%	105.00%	105.0%	-100.4%	-55.2	>5 min
9	0-10%	5.5%	100.00%	100.0%	-100.6%	-55.3	>5 min

Supplementary information:
 - % Values given with reference Pmax, in this case Pmax=55 kW

Q capability – Inductive							
Step	Active Power Setpoint (%Pmax)	Active Power measured (%Pmax)	Voltage setpoint (%Un)	Voltage measured (%Un)	Q _{max} Inductive (%Pmax)	Q _{max} Inductive (kVAr)	Test duration
1	>90%	90.6%	95.00%	95.0%	+39.6%	+21.8	>60 min
2	>90%	90.3%	105.00%	105.1%	+60.6%	+33.3	>60 min
3	>90%	90.2%	100.00%	100.0%	+51.5%	+28.3	>5 min
4	10-20%	13.0%	95.00%	95.0%	+98.4%	+54.1	>5 min
5	10-20%	13.8%	105.00%	105.0%	+100.2%	+55.1	>5 min
6	10-20%	13.7%	100.00%	100.0%	+100.2%	+55.1	>5 min
7	0-10%	4.9%	95.00%	95.0%	+98.4%	+54.1	>5 min
8	0-10%	4.7%	105.00%	105.0%	+100.2%	+55.1	>5 min
9	0-10%	4.7%	100.00%	100.0%	+100.2%	+55.1	>5 min


Supplementary information:
 - % Values given with reference Pmax, in this case Pmax=55 kW



4.4.1.2 Reactive power capability (Capabilities declared by the manufacturer)

The following graphic shows the reactive power capabilities of the UGE, based on the manufacturer's declaration, under voltage levels different from the normal operation range at normal temperature range.

The following diagram contains the manufacturer declared capability:



4.4.2 Reactive power control

The aim of this test is to verify the capability of the EUT of applying different reactive power control modes. It has been tested each control mode separately in the following points according to section 5.8.2 of NTs standard.

4.4.2.1 Reactive power control mode

The tests have been performed according to the procedures described by subclause 5.8.2.1 of the NTS 2.1 SEPE standard.

For this test, voltage has been set to its rated value and reactive power has been set to 0 before starting the test. Then, after keeping this 0-reactive power setpoints for 60 seconds, different reactive power setpoints have been applied and the time it takes for reactive power to stabilize has been measured.

The following conditions have been evaluated for each test performed:


Criteria	Comments	Result
CONDITIONS DURING MEASUREMENTS		
Active power between 20% and 100% of the maximum capacity of the UGE.	Test at 75% Pmax;	P
Voltage has been set to Un		P
the reactive power setpoint will be null at the start of the test		P
During the test, the reactive power settings as shown in Table 24 (of the standard) shall be established sequentially		P
Prior to performing a test shall be reserved for at least 1 minute without sending new reactive power settings.		P
Report result table indicates:		P
In the measured Q column: the reactive power measured in the UGE terminals.		P
In column t measured: the time it takes to stabilize at the new reactive power value after receiving a new setpoint, taking into account the tolerances Indicated in Table 24.		P
ACCEPTANCE CRITERIA		
The UGE is capable of modifying the reactive power output of the UGE in the event of a reactive power setpoint change.		P
The measured reactive power values are within the range defined in Table 24. (Setpoint $\pm 1,5 \% P_{max}$)		P
The response time, T_e , is less than the value indicated in Table 24 (60 s)	Settling time: Time of settling of reactive power within a tolerance band of $\pm 1.5\%$ of the measured reactive power setpoint.	P

The different setpoints applied and results are presented in the following graph and table:

Reactive Power Control Mode						
Step	Reactive Power Steps (%P _{max})	Set Point Q (%P _{max})	Measured Q (%P _{max})	ΔQ (%P _{max})	Max. Te (s)	Meas. Te (s)
1	0.0% → +10.0%	+10.0%	+10.4%	+0.4%	60	1.4
2	+10.0% → -10.0%	-10.0%	-10.2%	-0.2%	60	1.4
3	-10.0% → 0.0%	+0.0%	+1.2%	+1.2%	60	1.4

Supplementary information:

- In % Q meas. Inside of the tolerance: ±1.5%P_n
- P_{max} is considered as P_n due to the EUT can output P_{max}=55kW at whole working temperature range.



4.4.2.2 Voltage control mode

The procedure for this test consists of applying variations between the voltage setpoint and the voltage at the connection point to verify that the inverter is capable of exchanging reactive power to compensate that ΔU . Test has been done twice applying different gradients of 7% (Test 1) and 2% (Test 2).

The following conditions have been evaluated for each test performed:

Criteria	Comments	Result
CONDITIONS DURING MEASUREMENTS		
Active power between 20% and 100% of the maximum capacity of the UGE.	Active power was set at 33% Pmax during test.	P
The test conditions may be some of the following:		P
A power supply connected to the terminals of the UGE when the UGE is disconnected from the mains.		P
An element or method capable of modifying the voltage at the UGE connection point when the UGE is connected to the mains.		N/A
A fictitious signal simulating voltage changes connected to the UGE controller. The UGE must behave as if this signal were the voltage reading on its terminals.		N/A
Test bench, including all elements of reactive power management.		P
TEST SEQUENCE		
Prior to performing a test shall be reserved for at least 1 minute without sending new reactive power settings.		P
Test sequence as per Table 25 (of the standard). For voltage control mode with 7% slope.	Deviation according to the standard. See remarks of evaluation in Table 25.	P
Test sequence as per Table 26 (of the standard). For voltage control mode with 2% slope.	Deviation according to the standard. See remarks of evaluation in Table 26.	P
Report result table indicates:		P
Reactive power measured at terminals of the UGE after stabilization, calculated from voltage and current measurements.		P
Times t1 and t2, where t1 is the time in which the reactive power response reaches 90% of the final value, and t2 is the time in which it stabilizes in the final value, according to the definition of the Regulation (EU) 631/2016. Accuracy $\pm 5 \%Q_{max}$ ($\pm 5 \% * 30\%P_n = 0.015 \text{ p.u}$)	Accuracy $\pm 1.5 \%Q_{max}$	P

Criteria	Comments	Result
ACCEPTANCE CRITERIA		
The UGE is capable of modifying the reactive power output in the event of a voltage change.		P
The measured values of reactive power once stabilized in the final value are in the range according to the limits established in Table 25 and Table 26.		P
The response times t1 and t2 are equal to or less than the values specified in each case.		P

t₁ Response time: Time to reach the 90% of the expected reactive power response (ΔQ) at each change step.

t₂ Settling time: Time of settling of reactive power on a tolerance of $\pm 5\%$ Pn.

The table below shows measured values:

Test 1: Table 25								
U at NCP (%U _n)	U Setpoint (%U _n)	Exp. Q (%P _{max})	Meas. Q (%P _{max})	ΔQ (%P _{max})	Max. t ₁ (s)	Meas. t ₁ (s)	Max. t ₂ (s)	Meas. t ₂ (s)
100%	100%	0.0% ± 1.5%	+0.8%	+0.8%	--	--	--	--
102%	100%	-8.6% ± 1.5%	-8.9%	-0.3%	1.0	0.30	5.0	0.30
105%	100%	-21.4% ± 1.5%	-21.5%	-0.1%	1.0	0.10	5.0	0.10
98%	100%	8.6% ± 1.5%	+9.5%	+0.9%	1.0	0.30	5.0	0.30
95%	100%	21.4% ± 1.5%	+22.0%	+0.6%	1.0	0.30	5.0	0.30
100%	100%	0.0% ± 1.5%	+0.8%	+0.8%	1.0	0.10	5.0	0.10

Supplementary information:



- Slope 7% V1=1.07; Q1=-30%; V2=0.93; Q2=+30%.
- % Values are given in reference to P_{max}, in this case P_{max}= 55 kW.
- T₂ has been settled on a tolerance band of ±5%ΔQ. (It is more restricted than standard requirement indicated in subclause 5.8.2.2).

Test 2: Table 26								
U at NCP (%U _n)	U Setpoint (%U _n)	Exp. Q (%P _{max})	Meas. Q (%P _{max})	ΔQ (%P _{max})	Max. t ₁ (s)	Meas. t ₁ (s)	Max. t ₂ (s)	Meas. t ₂ (s)
100.0%	100.0%	0.0% ± 1.5%	+0.9%	+0.9%	--	--	--	--
102.0%	100.0%	-30.0% ± 1.5%	-30.8%	-0.8%	1.0	0.10	5.0	0.10
105.0%	100.0%	-75.0% ± 1.5%	-75.4%	-0.4%	1.0	0.10	5.0	0.10
98.0%	100.0%	30.0% ± 1.5%	+29.9%	-0.1%	1.0	0.50	5.0	0.50
95.0%	100.0%	75.0% ± 1.5%	+76.3%	+1.3%	1.0	0.10	5.0	0.10
100.0%	100.0%	0.0% ± 1.5%	+0.9%	+0.9%	1.0	0.50	5.0	0.50

Supplementary information:

- Slope 2% V1=1.02; Q1=-30%; V2=0.98; Q2=+30%
- % Values are given in reference to P_{max}, in this case P_{max}= 55 kW.
- T₂ has been settled on a tolerance band of ±5%ΔQ. (It is more restricted than standard requirement indicated in subclause 5.8.2.2).

Test results are represented in the following graphs:



4.4.2.3 Power Factor Control Mode

For this test, different power factor setpoints have been applied to verify reactive power variations as well as the settling time of the power factor after each setpoint change. Voltage has been set at its rated value during this test.


The following conditions have been evaluated for each test performed:

Criteria	Comments	Result
CONDITIONS DURING MEASUREMENTS		
Active power between 20% and 100% of the maximum capacity of the UGE.	Tests were performed at $P = 83\%P_{max}$	P
Voltage has been set to U_n		P
During the test the power factor setpoints have been established as shown in Table 27 (of NTS 2.1 SEPE standard).		P
Each measurement shall be at least 1 minute and at least 1 minute of stabilization shall be allowed prior to each recording.		P
Report result table indicates:		P
In the measured Q column: the reactive power measured in the UGE terminals.		P
Active power produced by the UGE at the time of Q measurement.		P
The time it takes the power factor to stabilize the in the $\pm 5\%$ band.	Reactive power has been used to determine this settling time	P
ACCEPTANCE CRITERIA		
The UGE is capable of modifying the reactive power output in the event of a power factor change.		P
The measured values of reactive power output from the power factor control are within the range defined in Table 27.	Tolerance = $\pm 1.5\% P_{max}$	P
The response time is less than the value indicated in Table 27		P

Results are presented in tables and graphs below:

Power Factor Control Mode							
Power Factor Setpoint	Power Factor Measured	Meas. P (%P _{max})	Exp Q (%P _{max})	Meas. Q (%P _{max})	Deviation (%P _{max})	Max. Settling Time	Meas. Settling Time (s)
0.950 inductive	0.950	83.1%	+26.3%	+26.9%	+0.6%	60 s	--
0.960 inductive	0.960	83.1%	+23.3%	+23.9%	+0.6%	60 s	0.7
0.970 inductive	0.970	83.0%	+20.0%	+20.6%	+0.6%	60 s	0.8
0.980 inductive	0.980	83.0%	+16.2%	+16.7%	+0.5%	60 s	0.9
0.990 inductive	0.990	83.0%	+11.4%	+11.8%	+0.4%	60 s	2.0
1.000	1.000	83.0%	0.0%	+1.2%	+1.2%	60 s	1.4
0.990 capacitive	0.990	83.0%	-11.4%	-11.6%	-0.2%	60 s	1.3
0.980 capacitive	0.980	83.0%	-16.2%	-16.5%	-0.3%	60 s	1.1
0.970 capacitive	0.970	83.0%	-20.0%	-20.4%	-0.4%	60 s	0.9
0.960 capacitive	0.960	82.9%	-23.3%	-23.8%	-0.5%	60 s	1.5
0.95 capacitive	0.950	82.9%	-26.3%	-26.9%	-0.6%	60 s	1.1

Supplementary information:
 - % Values given with reference P_{max}, in this case P_{max}=55 kW



4.5 CONTROL OF OSCILLATION DAMPING

This point is not applicable since the type of compliance assessment method for these requirements is not a test to be done over the EUT. The grid operator shall evaluate the compliance with the requirements stated in subclause 5.10 of the NTS standard using as a reference the simulation methods defined in this point of the standard. The conformity shall be confirmed by the grid operator through written communication.

4.6 RESPONSE DURING GRID FAULTS

The aim of this test is to determine whether the EUT is capable of detecting a grid fault and riding through it without disconnecting.


This point will be evaluated in the attached report: **2221 / 0269-7 – Attachment.I.**

For each voltage level at which the EUT is going to be tested, several test conditions will be done according to the following tables:


Category	Operation point	Fault Type
1	Partial Load	3-Phase
2	Full Load	3-Phase
3	Partial Load	2-Phase
4	Full Load	2-Phase

Load	Operation point
Full Load	>90%P _{max}
Partial Load (P _{med})	15-50%P _{max}
Minimum Load (P _{min})	<15%P _{max}

For the evaluation of these faults, the tolerances represented in the following picture have been taken into account:




The following profiles have been studied in order to prove compliance with the grid fault conditions provided by the standard, taking into consideration the criteria presented above:



Test	$U_{res}(p.u.)$	$T_f(ms)$	Fault Type	Load	Q/P_{max}	K
U5TP _{max}	5%Un ($\pm 5\%$)	≥ 200	3-Phase	Full	$0 \pm 10\%$	K=3.5
U5TP _{med}				Partial	$0 \pm 10\%$	K=3.5
U5BP _{max}			2-Phase	Full	$0 \pm 10\%$	K=3.5
U5BP _{med}				Partial	$0 \pm 10\%$	K=3.5
U40TP _{max}	40%Un ($\pm 5\%$)	≥ 850	3-Phase	Full	$0 \pm 10\%$	K=3.5
U40TP _{med}				Partial	$0 \pm 10\%$	K=3.5
U40BP _{max}			2-Phase	Full	$0 \pm 10\%$	K=3.5
U40BP _{med}				Partial	$0 \pm 10\%$	K=3.5
U75TP _{max}	75%Un ($\pm 5\%$)	≥ 1340	3-Phase	Full	$0 \pm 10\%$	K=3.5
U75TP _{med}				Partial	$0 \pm 10\%$	K=3.5
U75TP _{med} Q _{max}					Q_{max}/P_{max}	K=3.5
U75TP _{med} Q _{min}				Q_{min}/P_{max}	K=3.5	
U75TP _{min}			P _{min}	$0 \pm 10\%$	K=6	
U75BP _{max}			2-Phase	Full	$0 \pm 10\%$	K=3.5
U75BP _{med}				Partial	$0 \pm 10\%$	K=3.5
U75BP _{min}				P _{min}	$0 \pm 10\%$	K=6

Note: this table is the one corresponding to tests performed by SGS in order to verify requirements of both of the tables 49 and 50 of the NTS at the same time.

Additionally, Injection of positive and negative sequence of reactive current have to follow the characteristic shown below:



The following conditions have been evaluated for each test performed

Criteria	Comments	Result
TEST BENCH CONDITIONS		
For Photovoltaic UGE: The use of a test bench is permitted for testing the UGE, the presence of photovoltaic panels is not necessary, and the use of a DC source is permitted instead.		P
GENERAL		
The evolution of the voltage during the tests should remain above the curve indicated in Figure 25 of NTS V2.1 SEPE, considering the tolerance margins indicated.		P
Two consecutive tests shall be carried out for each type (or category) of test. This must be understood as between one test and another, no intermediate failed test has been performed under the same conditions.		P
For each test category, it is a necessary condition that the active and reactive power recorded prior to the creation of the voltage dip is within the ranges defined in the standard.		P
FOR UGE MPE < 110 kV Several voltage dips will be generated, corresponding to the requirement established in Figure 26, which are enumerated according to the first column of Table 49.		P
FOR UGE MPE ≥ 110 kV Several voltage dips will be generated, corresponding to the requirement established in Figure 26, which are enumerated according to the first column of Table 50.		N/A
The following parameters have been used as defined in the standard: t_0 , t_i , t_a , t_r , t_e , t_d , t_f .		P
The pre-fault recorded time ($t_i - t_0$) must be at least 60 seconds		P

Criteria	Comments	Result
The post-fault recording time (tf-td) should be at least 10 seconds or until a damped response is appreciated.		P
Information evaluated and documented according to Tables: 51, 52 and 53 of NTS V2.1 SEPE	Result tables and graphs have been included in Attachment I of this report.	P
Continuity of supply for Wind UGE:		N/A
It shall be verified that there is no disconnection of the UGE during the application of the voltage dip in 2 consecutive tests corresponding to the same category.		N/A
In the event of a disconnection in this sequence of tests (first 2 consecutive tests), the condition of continuity of supply will be considered valid only when in the following 3 tests, corresponding to the same category, there is no disconnection of the UGE.		N/A
If the active power of the UGE is outside the limits established in the previous tables for its corresponding test, and there is no disconnection of the UGE, it will be considered invalid from the test but will not be computed for the purpose of considering it consecutive, i.e. it will be rejected.		N/A
Continuity of supply for Photovoltaic UGE:		P
If the UGE is disconnected during the application of the voltage dip, in one of two consecutive tests for each test category, the test will be considered as not passed.		P
REACTIVE CURRENT RAPID INJECTION: EVALUATION CRITERIA		
In those cases where $U_{res} < 20\%$ and there is a blockage of the power electronics as indicated in PO12.2, it is not necessary to check this requirement.	There is not a blockage of the power electronics in these cases	N/A
For current injection plots, the positive sequence apparent current shall be used.		P
For the calculation of the K-factors and the response times (t_r) and setting times (t_e), the gap depth (for both two-phase and three-phase faults) shall be evaluated from the positive and negative sequence voltages for a period of 100ms from the occurrence of the fault (t_i) to 20ms before its clearance (t_d).		P
The UGE of the MPE will be able to inject the required current increase, considering the tolerances, determined according to Figure 28, according to the times indicated below (see Figure 29), as long as there is no blocking condition of the power electronics:		P
The delay time for the start of the injection/current draw (t_a) should be a maximum of 20 ms.		P
The response time (t_r) from the start of injection/current draw until it reaches 90% of the required step response in the voltage error must be a maximum of $T_a + 50$ ms		P
The settling time (t_e) from the start of the current injection/absorption until the response		P

Criteria	Comments	Result
remains in the range +20% to -10% around the required response must be maximum 60 ms.		
A reduction in the reactive current will be allowed in the positive and negative sequences with respect to the current values required in Figure 28, provided that at least the injected current is greater than or equal to the nominal apparent current. This means that the sum of the real RMS currents, equivalent to the total current, must be greater than or equal to 1 p.u.		P
In the case of fulfilling the previous condition, the test will be considered valid if one of the following two conditions is met: 1. The positive and negative sequence components will be limited in the same proportion. 2. The positive sequence component will be greater than 40% of the nominal apparent current.		P
ACTIVE POWER RECOVERY CRITERIA AFTER VOLTAGE DIP		
If the U_{res} at the terminals of the UGE does not fall below 0.5 p.u., the UGE must reach 95% of the predisturbance power (if the primary resource permits) within less than 1 second once the voltage reaches or exceeds 0.85 p.u. and must reach the pre-disturbance power (if the primary resource permits) within a further 2 s.		P
If the U_{res} in terminals of the UGE drops by 0.5 p.u. but it does not fall below 0.2 p.u., the UGE must reach 95% of the power prior to the disturbance in less than 2 s once the voltage reaches or exceeds 0.85 p.u. and it must reach the power before the disturbance in a time of less than 2 additional s.		P
If the U_{res} at the terminals of the UGE falls below 0.2 p.u., the UGE must reach 95% of the pre-disturbance power within 3 s once the voltage reaches or exceeds 0.85 p.u. and must reach the pre-disturbance power within a further 2 s		P

Result tables and graphs have been included in the attachment **2221 / 0269-7 – Attachment.I** of this report.

4.7 ISLANDING REQUIREMENTS

This point is not applicable since the type of compliance assessment method for these requirements is not a test to be done over the EUT. In case of a request by the grid operator, compliance with the requirements stated in the clause 5.13 of the NTS SEPE standard shall be evaluated, using as a reference the simulation methods defined in this point of the standard.

5 PICTURES


Front view



Back view



Internal view




Serial number of model



6 ELECTRICAL SCHEMES

The picture below shows internal wiring scheme of the inverter:



-----END OF REPORT-----